



**WESTERN MARINE CONSTRUCTION INC.**

2775 HARBOR AVE SW  
SUITE A  
SEATTLE, WASHINGTON 98126  
(206) 622-9161  
FAX (206) 622-9170

USACE, Alaska District  
Mr. Ron Broyles  
PO Box 6898  
Elmendorf ASB, AK 99506-6898

June 30, 2011

RE: Pipeline Pressure Test Certification for Bulk Fuel Construction, Gustavus  
Contract No. W911KB-07-D-0016 T.O. 0005

Dear Mr. Ron Broyles,

All welds on installed pipeline under the subject contract were pressure tested at 125 psi as required by the contract specifications. All welds were doped with soapy water to check their integrity and all welds passed inspection.

Sincerely,

Kathy Lochman

Contractor Quality Control  
Western Marine Construction